

**OB1 - <offline>**

"PRINCIPAL"        bucle principal del programa

**Nombre:**                                **Familia:**

**Autor:**                                **Versión:** 0.1

**Versión del bloque:** 2

**Hora y fecha Código:**                20/06/2007 17:31:59

**Interface:**                            15/02/1996 16:51:12

**Longitud (bloque / código / datos):** 00162    00028    00022

Nombre	Tipo de datos	Dirección	Comentario
TEMP		0.0	
OB1_EV_CLASS	Byte	0.0	Bits 0-3 = 1 (Coming event), Bits 4-7 = 1 (Event class 1)
OB1_SCAN_1	Byte	1.0	1 (Cold restart scan 1 of OB 1), 3 (Scan 2-n of OB 1)
OB1_PRIORITY	Byte	2.0	1 (Priority of 1 is lowest)
OB1_OB_NUMBR	Byte	3.0	1 (Organization block 1, OB1)
OB1_RESERVED_1	Byte	4.0	Reserved for system
OB1_RESERVED_2	Byte	5.0	Reserved for system
OB1_PREV_CYCLE	Int	6.0	Cycle time of previous OB1 scan (milliseconds)
OB1_MIN_CYCLE	Int	8.0	Minimum cycle time of OB1 (milliseconds)
OB1_MAX_CYCLE	Int	10.0	Maximum cycle time of OB1 (milliseconds)
OB1_DATE_TIME	Date_And_Time	12.0	Date and time OB1 started

**Bloque: OB1    principal**

Segm.: 1        NUEVO ARRANQUE

```
L        #OB1_SCAN_1
L        1
==I
=        "M_NEWSTART"
```

Segm.: 2        Condiciones generales

```
CALL    "CONDICIONES__GENERALES"
```